

Big Mesa Water Report

Month	Billed Gallons	HAA5*	TTHM*	Microbiological Sample
Apr-21	837,250	N/A	N/A	Absent
May-21	1,568,180	8.08	40.8	Absent
Jun-21	1,875,470	4.53	60.8	Absent
Jul-21	2,017,240	N/A	N/A	Absent
Aug-21	1,420,740	10.2	55.1	Absent
Sep-21	1,897,686	12.6	91.8	Absent
Oct-21	1,301,440	N/A	N/A	Absent
Nov-21	823,580	9.96	46.8	Absent
Dec-21	452,890	14.4	71	Absent
Jan-21	449,290	N/A	N/A	Absent
Feb-21	632,890	12.6	61.2	Absent
Mar-21	415,620	N/A	N/A	Absent
Apr-21	892,560	7.83	63.6	Absent
May-21	964,170	9.63	52.3	Absent

*Note: maximum contaminant level (MCL) for both Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) is 60 and 80, respectfully. These tests are performed quarterly.