

Big Mesa Water Report

Month	Billed Gallons	HAA5*	TTHM*	Microbiological Sample
Sep-20	1,897,686	12.6	91.8	Absent
Oct-20	1,301,440	N/A	N/A	Absent
Nov-20	823,580	9.96	46.8	Absent
Dec-20	452,890	14.4	71	Absent
Jan-21	449,290	N/A	N/A	Absent
Feb-21	632,890	12.6	61.2	Absent
Mar-21	415,620	N/A	N/A	Absent
Apr-21	892,560	7.83	63.6	Absent
May-21	964,170	9.63	52.3	Absent
Jun-21	1,752,740	6.38	65.8	Absent
Jul-21	1,473,520	N/A	N/A	Absent
Aug-21	1,967,128	9.9	58.6	Absent
Sep-21	1,758,613	N/A	N/A	Absent
Oct-21	814,240	6.93	59.5	Absent

*Note: maximum contaminant level (MCL) for both Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) is 60 and 80, respectfully. These tests are performed quarterly.